






# APPROVAL SHEET

## Wall Ductwork



Job Name:		
Dealer:		
Model	Duct Size	Required Fan
P.O. #:	By:	Date:
<b>Fabrication cannot begin until sheet is signed</b>		
Approved by		Date



16 Gauge  
Canaopy Collar

### Specifications

Sturdi-Bilt "DW" Series Ductwork: 16 Ga corrosion resistant Aluminized Steel. All Externally Welded NFPA Code #96 Construction, painted welds for additional corrosion resistance. Ductwork complete with built in 16 Gauge All Welded Curb Adapter for Slide In Installation and 16 Gal All Welded Exhaust Collar for Easy Installation on canopy. Complies with International Mechanical Code Type I Ductwork. Includes installation instructions. All wall duct installations must meet International Mechanical Code Chapter 5 and National Fire Protection Code #96

8132 Puritan Avenue, Detroit, Michigan, 48238, Phone Toll Free - 1-800-521-2895 Fax Toll Free 1-800-444-2895