




APPROVAL SHEET



Wall Ductwork


Job Name:		
Dealer:		
Model	Duct Size	Required Fan
P.O. #:	By:	Date:
Fabrication cannot begin until sheet is signed		
Approved by		Date



WALL CURB

*Wall Curb
Supplied with
Wall Fan*

SQUARE CURB ADAPTER



Duct Collar

Specifications

Sturdi-Bilt "DW" Series **Ductwork**: 16 Ga corrosion resistant Aluminized Steel. All Externally Welded NFPA Code #96 Construction, painted welds for additional corrosion resistance. Ductwork complete with built in 16 Gauge All Welded Curb Adapter for Slide In Installation and 16 Gal All Welded Exhaust Collar for Easy Installation on canopy. Complies with International Mechanical Code Type I Ductwork. Includes installation instructions. All wall duct installations must meet International Mechanical Code Chapter 5 and National Fire Protection Code #96