





CANOPIES, UPDRAFTS, DUCTWORK, EXHAUST AND MAKE UP AIR FANS

APPROVAL SHEET

Wall Make Up Air Ductwork



Job Name:			
Dealer:			
MUA Fan Model	# Ducts	Duct Model	CFM
P.O. #:	By:		Date:
Fabrication cannot begin until			sheet is signed
Approved by			Date



Specifications

- DWM Series Wall Make Up Duct:** 12" Diameter by 15ft Long Flexible Expandable Metallic Make Up Air Duct, Round Collar(s) to be attached to the Make Up Air Canopy, and 42" High x 22 Gauge Aluminized Steel Duct Jack with Collar(s) for Make Up Air Duct
- "1" (1) Length of Duct "2" (2) Length of Duct "3" (3) Length of Duct
- For "FWME" For "FWM" For "FWMF"
- NFPA #96 Fire Dampers** UL Listed, Welded to the make up air Canopy