




APPROVAL SHEET



Conveyor Oven Canopys "C1" Series



"C1S" SeriesConveyor Oven Canopy: Constructed of minimum 20 Gauge Stainless Steel Where Shows, 20 Gauge Minimum Aluminized Steel back and Top, Welded Construction. 12" Overhang single deck ovens. Air Filter Panel. Ceiling Hung, mounts directly over the oven. International Mechanical Type II Hood, NSF Listed. All Canopys custom built to fit specified Conveyor Oven, Oven Make and Model must be specified. "Top Mount": Mounts directly above flat top ovens "Straddle Moutt": Slightly larrger so that it can slide down over the control panel. "C1A" SeriesConveyor Oven Canopy: Same as above, only constructed of all minimum 20 Gauge Aluminzed Steel, Painted Hammertone Gray exposed Front and Ends. Type 1 NFPA #96 Construction: Constructed of 18 Gauge all externally welded construction, 6" Side Overhang, UL Grease Listed Baffle Filters, pitched gutter, grease cup. Flue: Canopy does not ventilate flue. Direct Vent Flue Vent is required.